CITY OF SPRINGFIELD INTEROFFICE MEMORANDUM

TO:

Robert R. Schaefer

DATE: July 17, 1992

Superintendent of Sanitary Services

DEPT.: PW - Sanitary Services

RE: 400-500 block West Sunshine

See attached study of sewer connections. Please let me know if you have any questions or we can do anything else.

J. Randall Lyman

Sewer Surveillance and Billing Supervisor

JRL/jb

Attachment

cc: Stephen A. Meyer, Sanitary Engineer File (2)

CITY OF SPRINGFIELD INTEROFFICE MEMORANDUM

TO: J Randall Lyman

DATE: July 16, 1992

DEPT.: Surveillance, Enforcement & Billing

SUBJECT: Block bounded by Sunshine, Campbell, Wedgewood, and University streets.

Per your memo of July 14, 1992, Karen Chandler, Gene Pabst, and myself conducted a dye survey of this area. Please find below the results of this survey.

The following structures located within this area were found to be connected to the sanitary sewer.

Loftis Pawn Shop, 410 W. University Quality Muffler Shop, 403 W. Sunshine Mazzio's Pizza, 425 W. Sunshine TCBY, 433 W. Sunshine McDonald's 501 W. Sunshine Sunshine Center, 520 W. University

The structure located at 438 W. University, presently occupied by the "Dent Doctor" apparently is not connected to the sanitary sewer. The occupant indicated that he was having to use a chemical toilet because the bathroom would back-up after a day or two use. The private line is expose on the west side of the building and appears to run to the north. It doesn't appear that this structure can be served by the sanitary sewer.

Please find attached a map of the area with the structures located and how they are attached to the sanitary sewer as determined by this dye testing.

If you need any other information concerning this matter please don't hesitate to ask.

Bob Corson

Water Pollution Control Inspector III Surveillance, Enforcement & Billing



